

Ocean Academy

160 Rt. 9

Bayville, NJ 08721

Analytical Results for Lead

JR Henderson Labs, Inc.

123 Seaman Ave.

Beachwood, NJ 08722

732-341-1211

Lab #15083

J.R. HENDERSON LABS, INC.

123 Seaman Ave.
Beachwood, New Jersey 08722

Potable Water & Wastewater Analysis
Atomic Absorption
Gas Chromatography

(732) 341-1211
FAX (732) 505-1658
ID # 15083

State Certified
Drinking Water Laboratory
Consulting Service

Ocean Academy
160 Rt. 9
Bayville, NJ 08721

Sample Date: 7-8-17

SAMPLE #	SAMPLE LOCATION	SAMPLE TIME	ANALYTE NAME/CODE	RESULTS UG/L	ANALYTICAL METHOD	ANALYSIS DATE	ANALYSIS TIME
17-4659.1	Sink-Teachers' Lounge	09:00	LEAD/1030	<2.00	200.9	7/14/2017	09:21
17-4659.2	Slop Sink-Science	09:04	LEAD/1030	<2.00	200.9	7/14/2017	09:25
17-4659.3	Slop Sink-Janitor's Closet	09:09	LEAD/1030	6.00	200.9	7/14/2017	09:30
17-4659.4	Water Cooler-Hallway	09:20	LEAD/1030	5.00	200.9	7/14/2017	09:34
17-4659.5	Water Cooler-Staff Lounge	09:25	LEAD/1030	<2.00	200.9	7/14/2017	09:38
17-4659.6	Water Cooler(Fish Tank)-Hallway	09:30	LEAD/1030	<2.00	200.9	7/14/2017	09:55
17-4659.7	Cooler-Large Group Room	08:39	LEAD/1030	<2.00	200.9	7/14/2017	10:00
17-4659.8	Three Bay Sink-Kitchen	08:47	LEAD/1030	<2.00	200.9	7/14/2017	10:04
17-4659.9	Middle Bath Sink-Ladies Room	08:49	LEAD/1030	<2.00	200.9	7/14/2017	10:08
17-4659.10	Middle Bath Sink-Mens Room	08:52	LEAD/1030	<2.00	200.9	7/14/2017	10:11
17-4659.11	Sink-Nurse's Office	08:56	LEAD/1030	<2.00	200.9	7/14/2017	10:51
17-4659.FB	Field Blank	08:39	LEAD/1030	<2.00	200.9	7/14/2017	08:08

UG/L=micrograms of contaminant per liter of water, equivalent to ppb (parts per billion).

Examined By: M. Ellis

Date: 7-14-17

Notes:

Chain of Custody

POTABLE WATER SAMPLING FOR LEAD CONCENTRATION SAMPLE COLLECTION FORM

CLIENT INFORMATION

Name: Ocean Academy
Address: 160 Rt. 9, Bayville, NJ 08721
Client Rep: Thomas McCann 908-770-2936

LAB INFORMATION

Name: JR Henderson Labs, Inc.
Address: 123 Seaman Ave., Beachwood, NJ
Proj.Mgr: Trevor Ellis 732-341-1211

SCHOOL/PROJECT INFORMATION

BLDG ID:
BLDG No/Name: Ocean Academy
BLDG Address: 160 Rt. 9, Bayville, NJ 08721
Contact Name & Numbers: Thomas McCann 908-770-2936

(0) Yr. Built:	(1) Yr. 1st Add.:	(2) Yr. 2nd Add.:	(3) Yr. 1st Mod.:	(4) Yr. 2nd Mod.:

SAMPLING TEAM: *[Signature]*
DATE OF SAMPLING: 7/8/17

SAMPLE DATA

Sample Description ID (ID must match container label)						Drinking Water Outlet Information			
Sample #	Floor	Functional Space Code	IN/BY	Room Number	Sampler/Outlet Code	Sampled Outlet Location/Coordinates/number	0 Seconds	30 Seconds	Time of collection (24hr)
1	1	TL		Teachers Lounge.		Sink	X		9:00
2	1	EC		Science		Slop Sink	X		9:04
3	1	Slop Sink		Janitor's Closet		Slop Sink	X		9:09
4	1	WC		Hallway		Water cooler	X		9:20
5	1	WC		Staff Lounge		Water cooler	X		9:25
6	1	WC		Hallway		Water cooler (Fish Tank)	X		9:30

All containers are pre-cleaned/ 250 ml plastic bottles preserved w HNO₃ @ pH<2 by field__ or to be preserved by lab__

CHAIN OF CUSTODY

Relinquished By:	Date/Time:	Received By:	Date/Time:
<i>[Signature]</i>	7/8/17 9:35		

Method of shipment/delivery: Fed-Ex Hand Delivery US Mail UPS Courier Other: _____

INSTRUCTIONS TO THE LABORATORY

Analyze both initial and follow up samples ___ Other: ___ Follow QAPP instructions	Lab: JR Henderson Labs Contact: Stacey Yuro	Report Results to: ___ Phone 908-770-2936 X Email: tmccann@oceanmhs.org ___ Fax
Comments: Provide Laboratory Data Report (LDR) Package and Chain of Custody		

Chain of Custody

POTABLE WATER SAMPLING FOR LEAD CONCENTRATION SAMPLE COLLECTION FORM

CLIENT INFORMATION

Name: Ocean Academy
Address: 160 Rt. 9, Bayville, NJ 08721
Client Rep: Thomas McCann 908-770-2936

LAB INFORMATION

Name: JR Henderson Labs, Inc.
Address: 123 Seaman Ave., Beachwood, NJ
Proj.Mgr: Trevor Ellis 732-341-1211

SCHOOL/PROJECT INFORMATION

BLDG ID:				
BLDG No/Name: Ocean Academy				
BLDG Address: 160 Rt. 9, Bayville, NJ 08721				
Contact Name & Numbers: Thomas McCann 908-770-2936				
(0) Yr. Built:	(1) Yr. 1st Add.:	(2) Yr. 2nd Add.:	(3) Yr. 1st Mod.:	(4) Yr. 2nd Mod.:

SAMPLING TEAM: *[Signature]*
DATE OF SAMPLING: 7/8/17

SAMPLE DATA

Sample Description ID (ID must match container label)						Drinking Water Outlet Information			
Sample #	Floor	Functional Space Code	IN/BY	Room Number	Sampler/Outlet Code	Sampled Outlet Location/Coordinates/number	0 Seconds	30 Seconds	Time of collection (24hr)
F B	1	WC		Large group room		Field Blank - Large group room / Coolers	X		8:39
7	1	WC		Large Group Room		Cooler	X		8:39
8	1	FP		Kitchen		Three bay Sink	X		8:47
9	1	Sinks		Women's Bathroom		Middle Sink	X		8:49
10	1	Sinks		Men's Bathroom		Middle Sink	X		8:52
11	1	NS		Nursing office		Sink	X		8:56

 All containers are pre-cleaned/ 250 ml plastic bottles preserved w HNO₃ @ pH<2 by field__ or to be preserved by lab__

CHAIN OF CUSTODY

Relinquished By:	Date/Time:	Received By:	Date/Time:
<i>[Signature]</i>	7/8/17 9:25		

Method of shipment/delivery: ___ Fed-Ex ___ Hand Delivery ___ US Mail ___ UPS ___ Courier ___ Other:___

INSTRUCTIONS TO THE LABORATORY

Analyze both initial and follow up samples ___ Other:	Lab: JR Henderson Labs	Report Results to:
___ Follow QAPP instructions	Contact: Stacey Yuro	___ Phone 908-770-2936
		X Email: tmccann@oceanmhs.org
		___ Fax

Comments: Provide Laboratory Data Report (LDR) Package and Chain of Custody

Ocean Academy
7/8/17 Lead Results

Field ID	Flushed Y/N	Laboratory sample ID	Laboratory Name	Lab Certification ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Concentration in ug/L	Reporting Limit (ug/L)	Dilution Factor	Digested (Y/N)	Qualifier
Sink-Teachers Lounge	N	17-4659.1	JRH Labs	15083	7/8/2017	09:00	200.9	7/14/2017	09:21	<2.00	2.00	1	N	
Slop Sink-Science	N	17-4659.2	JRH Labs	15083	7/8/2017	09:04	200.9	7/14/2017	09:25	<2.00	2.00	1	N	
Slop Sink-Janitor's Closet	N	17-4659.3	JRH Labs	15083	7/8/2017	09:09	200.9	7/14/2017	09:30	6.00	2.00	1	N	
Water Cooler-Hallway	N	17-4659.4	JRH Labs	15083	7/8/2017	09:20	200.9	7/14/2017	09:34	5.00	2.00	1	N	
Water Cooler-Staff Lounge	N	17-4659.5	JRH Labs	15083	7/8/2017	09:25	200.9	7/14/2017	09:38	<2.00	2.00	1	N	
Water Cooler(Fish Tank)-Hallway	N	17-4659.6	JRH Labs	15083	7/8/2017	09:30	200.9	7/14/2017	09:55	<2.00	2.00	1	N	
Cooler-Large Group Room	N	17-4659.7	JRH Labs	15083	7/8/2017	08:39	200.9	7/14/2017	10:00	<2.00	2.00	1	N	
Three Bay Sink-Kitchen	N	17-4659.8	JRH Labs	15083	7/8/2017	08:47	200.9	7/14/2017	10:04	<2.00	2.00	1	N	
Middle Bath Sink-Ladies Room	N	17-4659.9	JRH Labs	15083	7/8/2017	08:49	200.9	7/14/2017	10:08	<2.00	2.00	1	N	
Middle Bath Sink-Mens Room	N	17-4659.10	JRH Labs	15083	7/8/2017	08:52	200.9	7/14/2017	10:11	<2.00	2.00	1	N	
Sink-Nurse's Office	N	17-4659.11	JRH Labs	15083	7/8/2017	08:56	200.9	7/14/2017	10:51	<2.00	2.00	1	N	
Field Blank	N	17-4659.FB	JRH Labs	15083	7/8/2017	08:39	200.9	7/14/2017	08:08	<2.00	2.00	1	N	